ISTANBUL WATER QUALITY REPORT (MAY 2012)

Parametre	Turkish Standards TS 266 2005	World HEALTH Organization (WHO) 1999	Environment Protection Agency (EPA) 2003	Europe Community (EC) 1998	TREATMENT PLANT WATER QUALITY AVERAGE VALUES						
					B.Çekmece	İkitelli	Kağıthane	Emirli	Ömerli(Mur-Orhaniye)	Ömerli (Osmaniye)	Elmalı
PRIMARY STANDARDS (MICROBIOLOGIAL), EMS/100 mL											
Turbidity (NTU)	1,0	5,0	1,0	1,0	0,2	0,2	0,2	0,3	0,3	0,3	0,3
PRIMARY STANDARDS (DISINFECTION BY-PRODUCTS), mg/L											
Coliform Bacteria	< 1	0	< 1	0	0	0	0	0	0	0	
PRIMARY STANDARDS(INORGANIC CHEMICALS), mg/L											
Total Trihalomethanes	100	460	80	100	61,3	25,5	35,1	23,4	27,0	23,3	29,3
Bromate	10	10	10	10	-	< 4,1	-	-	-	-	< 4,1
PRIMARY STANDARDS (INORGANIC CHEMICALS), mg/L											
Aluminium	0,200	0,200	0,200	0,200	0,07	< 0,05	0,06	< 0,05	0,05	< 0,05	< 0,05
Arsenic	0,01	0,01	0,01	0,01	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002
Barium	-	0,7	2,0	-	0,05	0,02	0,02	0,03	0,03	0,02	0,02
Cadmium	0,005	0,003	0,005	0,005	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002
Chromium	0,05	0,05	0,10	0,05	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Bromide	-	-	-	-	0,05	< 0,05	< 0,05	< 0,05	< 0,05	< 0,05	< 0,05
Fluoride	1,5	1,5	2,0	1,5	0,17	0,07	0,06	0,06	0,05	0,05	0,06
Cyanide	0,05	0,07	0,20	0,05	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Lead	0,01	0,01	0,015	0,010	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01
Mercury	0,001	0,001	0,002	0,001	0,000	0,000	0,000	0,000	0,000	0,000	0,00
Nitrate (as NO_3^-)	50	50	45	50	4,41	1,08	1,01	1,33	1,98	2,12	4,76
Selenium	0,01	0,01	0,05	0,01	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01
Silver	-	0,1	0,10	-	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Antimony	0,005	0,020	0,006	0,005	< 0,005	< 0,005	< 0,005	< 0,005	< 0,005	< 0,005	< 0,005
Berillium	--	--	0,004	-	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002
SECONDARY STANDARDS-AESTHETIC STANDARDS (mg/l)											
Chloride	250	250	250	250	31	31	28	38	29	28	63
Color (units)	20	15	15	-	2,5	2,5	2,5	2,5	2,5	2,5	2,5
Copper	2,0	2,0	1,0	2,0	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Iron	0,2	0,3	0,3	0,2	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Manganese	0,05	0,1	0,05	0,05	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Odor CausingGeosmin	-	-	-	-	0,9	0,9	1,0	1,1	1,8	1,8	< 0,5
Compounds MID	-	-	-	-	1,9	0,7	1,8	2,7	7,4	7,0	0,8
PH	6,5-9,5	6,5 - 8,0	6,5 - 8,5	6,5 - 9,5	7,2	7,2	7,3	7,3	7,3	7,3	7,0
Sulphate	250	500	250	250	85,0	46,0	45,4	10,7	31,2	32,0	73,8
Total Dissolved Solids	- -	1000	500	- -	350	210	214	203	175	170	285
Zinc	-	3,0	5,0	-	< 0,1	< 0,1	< 0,1	< 0,1	< 0,1	< 0,1	< 0,1
ADDITIONAL PARAMETERS (mg/l)											
Calcium	-	300	-	-	62,5	48,1	45,5	51,3	38,7	36,4	42,8
Hardness as ($CaCO_3$)	-	500	-	-	207	144	139	147	106	109	136
Magnesium	-	-	-	-	12,3	3,9	5,0	4,4	4,1	5,2	7,4
Potassium	-	-	-	-	3,43	1,85	1,74	1,08	1,57	1,61	2,90
Sodium	200	200	-	200	32,9	13,1	13,2	7,2	11,9	12,3	35,2
Residual Chlorine	-	5,0	4,0	-	1,4	1,3	1,0	1,4	1,3	1,4	1,0
Ammonia	0,5	1,5	-	0,5	< 0,03	< 0,03	< 0,03	< 0,03	< 0,03	< 0,03	< 0,03