ISTANBUL WATER QUALITY REPORT (MAY 2013)

Parametre	Turkish Standards TS 266 2005	World HEALTH Organization (WHO) 1999	Environment Protection Agency (EPA) 2003	Europe Community (EC) 1998	TREATMENT PLANT WATER QUALITY AVERAGE VALUES						
					B.Çekmece	İkitelli	Kağıthane	Emirli	Ömerli(Mur-Orhaniye)	Ömerli (Osmaniye)	Elmalı
PRIMARY STANDARDS (MICROBIOLOGIAL), EMS/100 mL											
Turbidity (NTU)	1,0	5,0	1,0	1,0	0,2	0,3	0,1	0,2	0,2	0,1	0,3
PRIMARY STANDARDS (DISINFECTION BY-PRODUCTS), mg/L											
Coliform Bacteria	< 1	0	< 1	0	0	0	0	0	0	0	0
PRIMARY STANDARDS(INORGANIC CHEMICALS), mg/L											
Total Trihalomethanes	100	460	80	100	68,5	24,9	18,4	28,9	20,6	20,0	47,6
Bromate	10	10	10	10	-	< 2	< 2	-	< 2	< 2	< 2
PRIMARY STANDARDS (INORGANIC CHEMICALS), mg/L											
Aluminium	0,200	0,200	0,200	0,200	0,07	< 0,05	0,07	< 0,05	0,08	0,06	< 0,05
Arsenic	0,01	0,01	0,01	0,01	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002
Barium	-	0,7	2,0	-	0,03	0,02	0,02	0,03	0,02	0,02	0,02
Cadmium	0,005	0,003	0,005	0,005	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002
Chromium	0,05	0,05	0,10	0,05	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Bromide	-	-	-	-	0,05	< 0,05	0,06	< 0,05	< 0,05	< 0,05	< 0,05
Fluoride	1,5	1,5	2,0	1,5	0,16	0,06	0,05	0,07	0,06	0,06	0,06
Cyanide	0,05	0,07	0,20	0,05	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Lead	0,01	0,01	0,015	0,010	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01
Mercury	0,001	0,001	0,002	0,001	0,000	0,000	0,000	0,000	0,000	0,000	0,000
Nitrate (as NO_3^-)	50	50	45	50	4,39	1,79	1,36	3,24	3,48	3,54	3,36
Selenium	0,01	0,01	0,05	0,01	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01	< 0,01
Silver	-	0,1	0,10	-	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Antimony	0,005	0,020	0,006	0,005	< 0,005	< 0,005	< 0,005	< 0,005	< 0,005	< 0,005	< 0,005
Berillium	--	--	0,004	-	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002	< 0,002
SECONDARY STANDARDS-AESTHETIC STANDARDS (mg/l)											
Chloride	250	250	250	250	50	31	31,7	42,9	25,0	25,2	69
Color (units)	20	15	15	-	2,5	2,5	2,5	2,5	2,5	2,5	2,5
Copper	2,0	2,0	1,0	2,0	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Iron	0,2	0,3	0,3	0,2	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Manganese	0,05	0,1	0,05	0,05	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Odor CausingGeosmin	-	-	-	-	< 0,5	< 0,5	0,6	< 0,5	0,7	0,7	0,6
Compounds MID	-	-	-	-	1,6	0,3	< 0,2	1,5	1,6	1,7	0,7
PH	6,5-9,5	6,5 - 8,0	6,5 - 8,5	6,5 - 9,5	7,3	7,3	7,0	7,2	7,4	7,4	7,2
Sulphate	250	500	250	250	97,0	51,2	63,5	20,0	33,1	32,9	79,5
Total Dissolved Solids	- -	1000	500	- -	337	219	224	221	182	183	298
Zinc	-	3,0	5,0	-	< 0,1	< 0,1	< 0,1	< 0,1	< 0,1	< 0,1	< 0,1
ADDITIONAL PARAMETERS (mg/l)											
Calcium	-	300	-	-	60,9	49,5	48,7	51,7	39,7	39,3	44,5
Hardness as ($CaCO_3$)	-	500	-	-	205	141	134	167	127	129	148
Magnesium	-	-	-	-	13,5	4,6	4,9	4,9	5,7	5,8	8,1
Potassium	-	-	-	-	2,83	1,81	2,00	1,74	1,81	1,81	3,15
Sodium	200	200	-	200	26,5	14,1	20,0	10,8	12,8	12,8	39,1
Residual Chlorine	-	5,0	4,0	-	1,3	1,1	1,0	1,2	1,0	1,0	1,3
Ammonia	0,5	1,5	-	0,5	< 0,03	< 0,03	< 0,03	< 0,03	< 0,03	< 0,03	< 0,03