

**DRINKING WATER TREATMENT PLANTS MONTHLY AVERAGE ANALYSIS REPORT - AUGUST 2021**

Parameter	Unit	Water Intended For Human Consumption Regulation	Ömerli				Cumhuriyet	Elmalı	Kağıthane		İkitelli		Taşoluk	Büyükdöğmece
			1	2	3	4			1	2	1	2		
<b>MICROBIOLOGICAL PARAMETERS</b>														
Coliform Bacteria	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0
E.coli	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0
Enterococci	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0
C.perfringens (including spores)	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0
<b>CHEMICAL PARAMETERS</b>														
Acrylamide	µg/L	0,1	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02
Antimony	µg/L	5,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Arsenic	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Benzene	µg/L	1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Benzo (a) pyrene	µg/L	0,01	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005
Boron	mg/L	1	0,05	0,05	0,05	0,03	0,05	0,04	0,03	0,04	0,03	0,02	0,02	0,08
Bromate	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Cadmium	µg/L	5	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Chromium	µg/L	50	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Copper	mg/L	2	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01
Cyanide	µg/L	50	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30
1,2-dichloroethane	µg/L	3	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Epichlorohydrin	µg/L	0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1
Fluoride	mg/L	1,5	0,05	0,06	0,07	0,07	0,05	0,06	0,06	0,05	0,07	0,04	0,03	0,14
Lead	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Mercury	µg/L	1	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2
Nickel	µg/L	20	<2,0	<2,0	<2,0	3,08	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Nitrate	mg/L	50	2,62	2,63	2,75	2,23	2,77	1,49	0,64	1,92	0,66	0,30	0,29	1,22
Nitrite	mg/L	0,5	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02
Total Pesticides	µg/L	0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5
Polycyclic Aromatic Hydrocarbons	µg/L	0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1
Selenium	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Tetrachloroethene	µg/L	10	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Trichloroethene			<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Total Trihalomethanes	µg/L	100	28,4	25,7	30,4	25,1	30,0	35,4	42,8	46,8	31,9	33,6	36,0	49,0
Vinyl Chloride	µg/L	0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5
<b>INDICATOR PARAMETERS</b>														
Aluminium	µg/L	200	140,34	124,08	84,27	<20	22,78	39,24	53,43	55,22	50,98	47,97	71,23	59,31
Ammonium	mg/L	0,5	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05
Chloride	mg/L	250	30,7	30,1	31,6	52,2	53,6	100,7	60,1	66,2	44,8	31,3	32,2	96,9
Colour (Pt-Co)	mg/L	ACNAC	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Conductivity	µS/cm <sup>-1</sup>	2500	324	323	329	346	334	557	482	458	368	324	333	659
pH		≤9,5-6,5≤	7,18	7,18	7,26	6,94	6,87	6,94	6,96	6,88	7,07	7,13	7,22	7,16
Iron	µg/L	200	<20	<20	<20	35,67	82,96	<20	<20	59,57	<20	<20	<20	<20
Manganese	µg/L	50	15,46	26,37	21,53	<10	<10	<10	<10	<10	<10	<10	<10	<10
Odour		ACNAC	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun
Sulphate	mg/L	250	36,9	35,8	33,1	16,2	20,0	53,3	84,2	65,2	55,0	42,8	37,0	108,5
Sodium	mg/L	200	20,87	20,52	20,73	15,21	15,54	57,31	37,08	26,84	26,58	19,54	20,01	62,95
Taste		ACNAC	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun
Total Organic Carbon	mg/L	NAC	3,11	2,98	2,90	2,34	2,35	4,08	3,57	3,17	3,36	3,05	3,55	3,76
Turbidity	NTU	1	0,25	0,21	0,20	0,18	0,24	0,28	0,13	0,23	0,25	0,23	0,24	0,28
<b>RADIOACTIVITY PARAMETERS</b>														
Tritium	Bq/L	100	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0
Total Indicative Dose	mSv/yıl	0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1

ACNAC: Acceptable to consumers and no abnormal change

NAC : No abnormal change

NOTE : Analysis made by ISKI Clean Water Laboratory Branch Directorate. pH, Turbidity parameters made by plants laboratories.