

ISTANBUL WATER QUALITY REPORT (JANUARY 2017)

Parametre	Turkish Standards	World Health Organization	Environment Protection Agency (EPA)	Europe Community	TREATMENT PLANT WATER QUALITY AVERAGE VALUES				
	TS 266 2005	(WHO) 2011	(EPA) 2008	(EC) 1998	B.çekmece	İkitelli	Kağıthane	Ömerli	Cumhuriyet
Turbidity (NTU)	1,0	5,0	1,0	1,0	0,22	0,21	0,15	0,29	0,13
PRIMARY STANDARDS (MICROBIOLOGICAL), cfu/100 mL									
E.coli	0	0	0	0	0	0	0	0	0
Enterococci	0	0	-	0	0	0	0	0	0
Coliform Bacteria	0	0	0	0	0	0	0	0	0
PRIMARY STANDARDS (DISINFECTION BY-PRODUCTS), µg/L									
Total Trihalomethanes	100	460	80	100	33,8	16,9	9,5	15,7	28,6
Bromate	3	10	10	10	< 2,0	< 2,0	< 2,0	< 2,0	< 2,0
PRIMARY STANDARDS (INORGANIC CHEMICALS), mg/L									
Aluminium	0,200	0,100	0,200	0,200	0,040	0,044	0,019	0,043	0,007
Arsenic	0,01	0,01	0,01	0,01	0,0004	< 0,0003	< 0,0003	< 0,0003	< 0,0003
Boron	1,0	2,4	-	1,0	0,077	0,019	0,031	0,027	0,031
Nickel	0,02	0,02	-	0,02	0,003	0,001	0,002	< 0,001	0,003
Barium	-	0,7	2,0	-	0,059	0,025	0,029	0,029	0,025
Cadmium	0,005	0,003	0,005	0,005	< 0,0001	< 0,0001	< 0,0001	< 0,0001	< 0,0001
Chromium	0,05	0,05	0,10	0,05	< 0,0002	< 0,0002	< 0,0002	< 0,0002	0,0003
Bromide	-	-	-	-	0,07	0,03	0,04	0,03	< 0,01
Fluoride	1,5	1,5	2,0	1,5	0,184	0,055	0,040	0,044	0,072
Cyanide	0,05	0,07	0,20	0,05	< 0,02	< 0,02	< 0,02	< 0,02	< 0,02
Lead	0,01	0,01	0,015	0,010	< 0,0003	< 0,0003	< 0,0003	< 0,0003	< 0,0003
Mercury	0,001	0,001	0,002	0,001	< 0,0001	< 0,0001	< 0,0001	< 0,0001	< 0,0001
Nitrate	50	50	45	50	5,8	2,8	3,4	4,7	6,2
Selenium	0,01	0,01	0,05	0,01	< 0,0003	< 0,0003	< 0,0003	< 0,0003	< 0,0003
Silver	-	0,10	0,10	-	< 0,0002	< 0,0002	< 0,0002	< 0,0002	< 0,0002
Antimony	0,005	0,020	0,006	0,005	< 0,0002	< 0,0002	< 0,0002	< 0,0002	< 0,0002
Berillium	--	--	0,004	-	< 0,0001	< 0,0001	< 0,0001	< 0,0001	< 0,0001
SECONDARY STANDARDS-AESTHETIC STANDARDS (mg/L)									
Chloride	250	250	250	250	110	38	60	33	55
Color (PC units)	20	15	15	-	< 2,0	< 2,0	< 2,0	< 2,0	< 2,0
Copper	2,0	2,0	1,0	2,0	0,002	< 0,001	0,003	0,001	< 0,001
Iron	0,2	0,3	0,3	0,2	0,021	0,037	< 0,005	0,040	0,017
Manganese	0,05	0,1	0,05	0,05	0,004	< 0,002	0,012	0,007	< 0,002
Taste-Odor Causing Geosmin Compounds ng/L MIB	-	-	-	-	1,2	0,3	2,6	2,9	1,9
pH	6,5-9,5	6,5 - 8,0	6,5 - 8,5	6,5 - 9,5	7,5	7,4	7,0	7,1	6,8
Sulphate	250	500	250	250	98,8	44,6	87,5	40,1	19,6
Total Dissolved Solids	-	1000	500	-	357	204	258	324	279
Zinc	-	3,0	5,0	-	< 0,001	< 0,001	0,003	0,060	0,593
ADDITIONAL PARAMETERS (mg/L)									
Calcium	-	300	-	-	63,6	47,3	52,8	39,3	39,5
Hardness as (CaCO ₃)	-	500	-	-	218	151	168	126,4	133
Magnesium	-	-	-	-	14,5	5,5	10,2	7,5	7,1
Potassium	-	-	-	-	4,4	2,1	2,8	2,9	3,0
Sodium	200	200	-	200	56,4	16,6	32,8	20,5	16,3
Residual Chlorine	-	5,0	4,0	-	1,19	1,1	1,42	1,54	1,6
Ammonia	0,5	1,5	-	0,5	< 0,03	< 0,03	< 0,03	< 0,03	< 0,03

1 -Turbidity, pH, chloride, total hardness, and residual chlorine values are the monthly average values of the plant operation laboratory.

2 - Other parameters are the monthly average values performed at the Brunch Directorate of Clean Water Laboratory.

3 - The chlorine value shown here are the values of the end product, and the free chlorine level decreases over time.

This value is chosen to maintain a free chlorine at all points of the supply, and the free chlorine concentration level tested within the supply varies between 0.2 and 0.5 mg/L.