

DRINKING WATER TREATMENT PLANTS MONTHLY AVERAGE ANALYSIS REPORT - JUNE 2020

Parameter	Unit	Water Intended For Human Consumption Regulation	Ömerli				Cumhuriyet	Elmah	Kağıthane		İkitelli		Taşoluk	Büyükkçekmece
			1	2	3	4			1	2	1	2		
MICROBIOLOGICAL PARAMETERS														
Coliform Bacteria	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0
E.coli	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0
Enterococci	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0
C.perfringens (including spores)	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0
CHEMICAL PARAMETERS														
Acrylamide	µg/L	0,1	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02
Antimony	µg/L	5,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Arsenic	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Benzene	µg/L	1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Benzo (a) pyrene	µg/L	0,01	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005
Boron	mg/L	1	0,03	0,03	0,03	0,03	0,04	0,04	0,03	0,03	0,02	0,02	0,02	0,08
Bromate	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Cadmium	µg/L	5	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Chromium	µg/L	50	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Copper	mg/L	2	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01
Cyanide	µg/L	50	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30
1,2-dichloroethane	µg/L	3	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Epichlorohydrin	µg/L	0,1	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05
Fluoride	mg/L	1,5	0,06	0,07	0,07	0,08	0,08	0,08	0,07	0,08	0,07	0,07	0,06	0,20
Lead	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Mercury	µg/L	1	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2
Nickel	µg/L	20	<2,0	<2,0	<2,0	2,75	<2,0	2,62	<2,0	<2,0	<2,0	<2,0	<2,0	2,032
Nitrate	mg/L	50	3,89	3,85	3,90	3,41	3,26	4,60	0,80	2,46	0,63	0,50	0,45	0,19
Nitrite	mg/L	0,5	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02
Total Pesticides	µg/L	0,5	-	-	-	-	-	-	-	-	-	-	-	-
Polycyclic Aromatic Hydrocarbons	µg/L	0,1	-	-	-	-	-	-	-	-	-	-	-	-
Selenium	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Tetrachloroethene	µg/L	10	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Trichloroethene			<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Total Trihalomethanes	µg/L	100	17,90	16,24	21,08	18,06	28,50	25,98	26,06	44,02	27,10	30,84	21,14	47,26
Vinyl Chloride	µg/L	0,5	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1
INDICATOR PARAMETERS														
Aluminium	µg/L	200	67,74	72,03	78,84	<20	<20	37,05	41,14	27,85	47,98	55,03	74,40	100,91
Amonium	mg/L	0,5	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05
Chloride	mg/L	250	18,16	17,96	18,12	45,94	41,84	44,49	43,43	44,00	38,40	37,42	35,58	90,60
Colour (Pt-Co)	mg/L	ACNAC	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Conductivity	µS/cm ⁻¹	2500	327	326	322	382	335	417	435	372	405	398	367	663
pH		≤9,5-6,5≤	7,10	7,19	7,28	6,87	6,99	6,95	7,20	7,09	7,26	7,27	7,26	7,21
Iron	µg/L	200	<20	<20	<20	<20	72,13	<20	41,60	49,06	<20	<20	84,57	<20
Manganese	µg/L	50	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
Odour		ACNAC	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun
Sulphate	mg/L	250	37,38	31,96	29,06	15,16	18,46	48,64	61,70	31,44	51,26	50,62	37,48	91,66
Sodium	mg/L	200	12,31	12,43	10,38	11,14	12,32	29,63	23,88	16,12	21,74	21,04	20,34	56,76
Taste		ACNAC	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun
Total Organic Carbon	mg/L	NAC	2,45	2,46	2,46	2,04	2,12	3,65	2,94	2,41	2,89	2,83	2,84	3,68
Turbidity	NTU	1	0,16	0,11	0,14	0,17	0,19	0,21	0,17	0,14	0,20	0,20	0,25	0,11
RADIOACTIVITY PARAMETERS														
Tritium	Bq/L	100	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0	<3,0
Total Indicative Dose	mSv/yıl	0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1

ACNAC: Acceptable to consumers and no abnormal change

NAC : No abnormal change

NOTE : Analysis made by ISKI Clean Water Laboratory Branch Directorate. pH, Turbidity parameters made by plants laboratories.