

ISTANBUL WATER QUALITY REPORT MAY 2018

Parametre	Turkish Standards TS 266 2005	World Health Organization (WHO) 2011	Environment Protection Agency (EPA) 2008	Europe Community (EC) 1998	B.çekmece	İkitelli	Kağıthane	Ömerli	Cumhuriyet	Taşoluk
Turbidity (NTU)	1,0	5,0	1,0	1,0	0,17	0,15	0,11	0,22	0,17	0,16
PRIMARY STANDARDS (MICROBIOLOGICAL), cfu/100 mL										
E.coli	0	0	0	0	0	0	0	0	0	0
Enterococci	0	0	-	0	0	0	0	0	0	0
Coliform Bacteria	0	0	0	0	0	0	0	0	0	0
PRIMARY STANDARDS (DISINFECTION BY-PRODUCTS), µg/L										
Total Trihalomethanes	100	460	80	100	38,5	26,2	13,9	18,4	29,0	23,5
Bromate	3	10	10	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
PRIMARY STANDARDS (INORGANIC CHEMICALS), mg/L										
Aluminium	0,200	0,100	0,200	0,200	0,067	0,063	0,039	0,059	0,008	0,056
Arsenic	0,01	0,01	0,01	0,01	0,0005	0,0003	0,0004	<0,0003	<0,0003	<0,0003
Boron	1,0	2,4	-	1,0	0,069	0,022	0,035	0,023	0,033	0,019
Nickel	0,02	0,02	-	0,02	0,003	0,002	0,001	0,001	0,002	0,001
Barium	-	0,7	2,0	-	0,054	0,027	0,026	0,031	0,022	0,024
Cadmium	0,005	0,003	0,005	0,005	<0,0001	<0,0001	<0,0001	<0,0001	<0,0001	<0,0001
Chromium	0,05	0,05	0,10	0,05	0,000	<0,0002	<0,0002	<0,0002	0,0002	<0,0002
Bromide	-	-	-	-	0,03	<0,02	<0,02	<0,02	<0,02	<0,02
Fluoride	1,5	1,5	2,0	1,5	0,15	0,05	0,06	0,07	0,06	0,06
Cyanide	0,05	0,07	0,20	0,05	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02
Lead	0,01	0,01	0,015	0,010	<0,0003	<0,0003	<0,0003	<0,003	<0,0003	<0,0003
Mercury	0,001	0,001	0,002	0,001	<0,0001	<0,0001	<0,0001	<0,0001	<0,0001	<0,0001
Nitrate	50	50	45	50	6,51	2,05	2,56	2,99	4,31	1,58
Selenium	0,01	0,01	0,05	0,01	<0,0003	<0,0003	0,0006	<0,0003	<0,0003	<0,0003
Silver	-	0,10	0,10	-	<0,00002	<0,00002	<0,00002	<0,00002	<0,00002	<0,00002
Antimony	0,005	0,020	0,006	0,005	<0,0002	<0,0002	<0,0002	<0,0002	<0,0002	<0,0002
Berillium	--	--	0,004	-	<0,0001	<0,0001	<0,0001	<0,0001	<0,0001	<0,0001
SECONDARY STANDARDS-AESTHETIC STANDARDS (mg/L)										
Chloride	250	250	250	250	66,9	26,8	43,0	27,0	39,9	24,7
Color (PC units)	20	15	15	-	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Copper	2,0	2,0	1,0	2,0	0,002	<0,001	0,002	0,001	<0,001	<0,001
Iron	0,2	0,3	0,3	0,2	0,008	0,021	0,0	0,005	0,027	<0,005
Manganese	0,05	0,1	0,05	0,05	<0,002	0,003	0,002	0,002	<0,002	<0,002
Taste-Odor Causing Geosmin Compounds ng/L MIB	-	-	-	-	1,27	0,93	1,05	1,28	1,37	0,61
pH	6,5-9,5	6,5 - 8,0	6,5 - 8,5	6,5 - 9,5	7,14	7,32	6,83	7,27	6,94	7,71
Sulphate	250	500	250	250	83,3	45,3	91,7	22,7	16,6	35,8
Total Dissolved Solids	-	1000	500	-	357	204	258	193	199	186
Zinc	-	3,0	5,0	-	<0,001	0,006	0,006	0,017	0,225	0,001
ADDITIONAL PARAMETERS (mg/L)										
Calcium	-	300	-	-	70,8	51,6	58,4	50,1	49,0	45,9
Hardness as (CaCO ₃)	-	500	-	-	230	150	185	150	150	135
Magnesium	-	-	-	-	12,9	5,1	9,4	6,2	6,8	5,1
Potassium	-	-	-	-	4,6	2,7	3,9	2,1	2,3	2,5
Sodium	200	200	-	200	38,4	15,7	29,8	11,8	11,1	14,5
Residual Chlorine	-	5,0	4,0	-	1,37	1,00	1,10	1,34	1,25	1,50
Ammonia	0,5	1,5	-	0,5	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05

1 -Turbidity, pH and residual chlorine values are the monthly average values of the plant operation laboratory.

2 - Other parameters are the monthly average values performed at the Brunch Directorate of Clean Water Laboratory.

3 - The chlorine value shown here are the values of the end product,and the free chlorine level decreases over time.

This value is chosen to maintain a free chlorine at all points of the supply, and the free chlorine concentration level tested between 0.2 and 0.5 mg/L.