

ISTANBUL WATER AND SEWERAGE ADMINISTRATION

DRINKING WATER TREATMENT PLANTS MONTHLY AVERAGE ANALYSIS REPORT - MARCH 2023

Parameter	Unit	Water Intended For Human Consumption Regulation	Ömerli					Cumhuriyet	Elmalı	Kağıthane		İkitelli		Taşoluk	Büyükkçekmece
			1	2	3	4	5			1	2	1	2		
MICROBIOLOGICAL PARAMETERS															
Coliform Bacteria	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0
E.coli	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Enterococci	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0
C.perfringens (including spores)	cfu/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CHEMICAL PARAMETERS															
Acrylamide	µg/L	0,1	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02
Antimony	µg/L	5,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Arsenic	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Benzene	µg/L	1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Benzo (a) pyrene	µg/L	0,01	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005	<0,005
Boron	mg/L	1	0,04	0,04	0,04	0,02	0,02	0,04	0,03	0,04	0,04	0,02	0,02	0,01	0,07
Bromate	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Cadmium	µg/L	5	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Chromium	µg/L	50	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Copper	mg/L	2	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01	<0,01
Cyanide	µg/L	50	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30
1,2-dichloroethane	µg/L	3	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Epichlorohydrin	µg/L	0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1
Fluoride	mg/L	1,5	0,06	0,06	0,06	0,08	0,06	0,06	0,06	0,07	0,07	0,07	0,05	0,06	0,21
Lead	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Mercury	µg/L	1	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2	<0,2
Nickel	µg/L	20	<2,0	<2,0	<2,0	<2,0	<2,0	5,37	2,14	<2,0	4,6	<2,0	<2,0	<2,0	<2,0
Nitrate	mg/L	50	4,66	5,74	5,72	2,75	2,79	5,49	4,06	1,46	5,45	0,92	0,86	0,76	1,25
Nitrite	mg/L	0,5	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02	<0,02
Total Pesticides	µg/L	0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5
Polycyclic Aromatic Hydrocarbons	µg/L	0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1
Selenium	µg/L	10	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Tetrachloroethene	µg/L	10	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Trichloroethene	µg/L	10	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Total Trihalomethanes	µg/L	100	16,9	17,3	19,7	13,6	16,5	11,8	20,7	25,7	19,5	11,2	11,7	11,8	36,5
Vinyl Chloride	µg/L	0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5	<0,5
INDICATOR PARAMETERS															
Aluminium	µg/L	200	80,9	56,3	98,4	27,1	49,3	<20	28,9	48,2	<20	72,6	47,4	72,7	42,6
Amonium	mg/L	0,5	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05	<0,05
Chloride	mg/L	250	41,5	49,9	50,1	55,0	21,7	64,4	211,3	102,2	61,3	49,6	38,7	40,0	141,7
Colour (Pt-Co)	mg/L	ACNAC	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Conductivity	µS/cm ⁻¹	2500	486	484	492	515	492	429	964	750	433	450	419	413	846
pH		≤9,5-6,5≤	7,47	7,44	7,51	7,19	7,52	6,68	6,71	7,06	6,80	7,27	7,25	7,28	7,37
Iron	µg/L	200	<20	<20	<20	35,50	<20	40,28	<20	<20	39,20	<20	<20	<20	<20
Manganese	µg/L	50	<10	<10	<10	11,01	<10	<10	<10	<10	<10	<10	<10	<10	<10
Odour		ACNAC	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun
Sulphate	mg/L	250	38,2	37,5	36,6	16,8	40,5	19,9	75,5	103,5	19,2	50,2	36,5	40,4	93,7
Sodium	mg/L	200	36,7	42,3	42,2	18,3	17,6	20,2	173,4	70,6	22,2	30,8	24,0	22,5	104,0
Taste		ACNAC	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun	Uygun
Total Organic Carbon	mg/L	NAC	2,89	2,76	2,90	2,55	2,47	1,99	3,78	3,35	1,69	3,17	2,85	3,06	3,58
Turbidity	NTU	1	0,18	0,15	0,18	0,23	0,12	0,15	0,15	0,17	0,14	0,30	0,30	0,26	0,17
RADIOACTIVITY PARAMETERS															
Tritium	Bq/L	100	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0	<2,0
Total Indicative Dose	mSv/yıl	0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1	<0,1

ACNAC: Acceptable to consumers and no abnormal change
 NAC : No abnormal change

